



ChangeLog for 51.2V 280ah AllWeather WallMount & Indoor WallMount

S02T11- Corrected the cycle count logic to:
Cumulative discharge 80% (224 ah) = +1 Cycle count

S02T09- heater logic is whenever all (4) temperature sensors 1-4 reach below 0C the heater will turn on and draw a 4 amp discharge until all (4) temperature sensors 1-4 reach 6C the heater will power off. The heater will not function at 10% SOC or below.

S02T07- Added the rapid shutdown (RSD) feature when in closed loop communication with the EG4 18kPV in
Battery Type: Lithium
Lithium Brand: Lithium_01

*When this document was released S02T11 is the current publicly released firmware.
S02T11 includes all features from S02T09 & S02T07.
All updates in this changelog are done via RS232.*